



OSHA Compliance Checklist
Specific Purpose Equipment
(1910.306)

	O.K.	Action Needed
Cranes and Hoists		
1. Is a readily accessible means of disconnecting power provided?		
a. Is the disconnecting means capable of being locked in the open position?		
2. Is a limit switch or other device provided to prevent the load block from passing the safe upper limit of travel of any hoisting mechanism?		
3. Is at least 2 feet six inches provided as clearance to service parts?		
Data Processing Systems		
1. Is a disconnect means to disconnect the power to all electronic equipment in the data processing and computer rooms?		
a. Is the control readily accessible at the principal exit doors?		
b. Is a readily accessible means to disconnect the air conditioning to the computer ADP room?		